



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A. San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309


Water Quality Chemistry Services
Lead School Testing
Report Date: 6/19/18

Solana Beach School District
Solana Pacific Elementary

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1242843	06/07/18	05:48 AM	SAMPLE 1	3710020-CGB-A	< 5	ug/L
W1242844	06/07/18	05:45 AM	SAMPLE 2	3710020-CGB-B	< 5	ug/L
W1242845	06/07/18	05:42 AM	SAMPLE 3	3710020-CGB-C	< 5	ug/L
W1242846	06/07/18	05:38 AM	SAMPLE 4	3710020-CGB-D	< 5	ug/L
W1242847	06/07/18	05:36 AM	SAMPLE 5	3710020-CGB-E	< 5	ug/L

<u>Source</u>	<u>Source Description</u>
SAMPLE 1	Athletic fields area, freestanding double fixture, upper bubbler
SAMPLE 2	Near asphalt playground, two wall mount exterior fixture, upper right bubbler
SAMPLE 3	Room 102, two separate sinks w/faucet and bubbler, lower right sink, bubbler
SAMPLE 4	Main BLDG, interior lunch/food prep, sink with faucet and water dispenser, faucet
SAMPLE 5	Media room, hallway, two wallmount fixtures, left of staff workroom, lower right bubbler

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Tom Burger, Associate Chemist