



Santa Fe Irrigation District CONSUMER NOTICE Lead and Copper Water Sample Results

The Santa Fe Irrigation District is providing you with the lead and copper test results on the water sample collected at your location. Please share this notice with everyone who uses or drinks the water.

The results at: Solana Vista Elementary
780 Santa Victoria Solana Beach, CA 92075

Lead ND 0 ug/L and Copper 84 ug/L

The maximum contaminant level goal (MCLG) is the level of a contaminant in drinking water below which there are no known or expected risks to health. MCLGs allow for a margin of safety. The regulatory limits for lead and copper are called action levels. An exceedance occurs when the concentration of the lead or copper in more than 10 percent of the tap water samples exceeds an action level.

- The MCLG for lead is "0" and the action level is 15 ug/L (or .015 mg/L).
- The MCLG and action level for copper is 1,300 ug/L (or 1.3 mg/L).

Lead or copper action level exceedances will trigger corrosion control treatment or other requirements. We will notify all water users if our system exceeds the lead action level. For more information regarding lead and copper visit www.epa.gov/safewater/lead or www.epa.gov/dwreginfo/lead-and-copper-rule

For more information regarding your results please contact:

Santa Fe Irrigation District
5920 Linea Del Cielo
PO Box 409 Rancho Santa Fe, CA. 92067
(858)756-2424

This notice is sent to you by: Santa Fe Irrigation District Water System on 5/27/2016

May 27, 2016